

PLUMBING AND MECHANICAL
INTERPRETATION MANUAL



CODE: 2003 IRC

DATE:

CODE REF: M1411.3

3/31/2004

SUBJECT: Condensate Disposal Drains

Chapter 30 of the IRC regarding the sizing, slope, trapping, venting, and required cleanouts for indirect waste piping does not apply to air conditioning condensate drains.

Section M1411.3 of the IRC has requirements for air conditioning condensate drains and pans.

SIGNATURE: *Lonnie Erwin,*

Chief Plumbing and Mechanical Inspector
City of Dallas