

PLUMBING AND MECHANICAL
INTERPRETATION MANUAL



CODE: 2006 IFGC & IRC

DATE:

CODE REF: Section 405.1

3/14/2008

SUBJECT: Product Approval

John Lott
Norton McMurray Manufacturing Company
2570 Kaneville Cort
Geneva, Illinois 60134

RE: Approval for Normac-Riser

Mr. Lott,

I have reviewed your request for approval of the Normac-Riser and concluded from the information submitted to my office for approval that these products are approved for use within the City of Dallas.

This product must be installed according to manufacturer's installation instructions, product listings and all applicable codes. When the Normac-Riser is used in place of a bent steel riser for a transition from poly pipe to steel it must be supported in an approved manner. As with all new products I would ask that 4 sets of training literature and be provided for each of our four (4) district building inspection offices. This material can be forwarded to my office for distribution.

Therefore, use of this product may begin immediately in the City of Dallas.

SIGNATURE: *Lonnie Erwin,*
Chief Plumbing and Mechanical Inspector
City of Dallas