

PLUMBING AND MECHANICAL
INTERPRETATION MANUAL



CODE: 2003 IPC & IRC

DATE:

CODE REF: IPC 417.5.2 IRC P2709.2

3/27/2007

SUBJECT: Plumbing Product Approval

3/28/2007

Rocky Hill
Protecto Wrap
Architectural Sales Manager
1955 S. Cherokee St. Denver, CO.
80223
e-mail: rocky@protectowrap.com



CITY OF DALLAS

RE: Approval for Protecto Wrap AFM and AFM-WM

Mr. Hill,

I have reviewed your request for approval of the Protecto Wrap AFM and AFM-WM water proofing membrane and concluded from the information submitted to my office for approval that these products are approved for use within the City of Dallas with the following provisions:

1. Product must be installed in accordance with ICC ESR-1127 and manufacturer's installation instructions including verification of compliance of section 4.1.1 of ESR-1127 for the proper application of # 6000 water based primer or # 80 water based primer for exterior applications.
2. Verification of compliance should be in the form of a letter signed and sealed by a Registered Engineer in the State of Texas, to certify the product was installed as required by ICC ESR-1127 report and manufacturer's installation instructions. This letter must be submitted before the plumbing final to the district plumbing inspector and will be part of the permanent permit record for the project and may cover all material installed on the project.

This product must be installed according to manufacturer's installation instructions, product listings and the 2003 IRC and IPC codes. As with all new products I would ask those 4 sets of training literature and any product samples be provided for each of our four (4) district building inspection offices. This material can be forwarded to my office for distribution.

Therefore, use of this product may begin immediately in the City of Dallas.

SIGNATURE: *Lonnie Erwin,*

Chief Plumbing and Mechanical Inspector
City of Dallas