

PLUMBING AND MECHANICAL
INTERPRETATION MANUAL



CODE: 2003 IMC

DATE:

CODE REF: REF: 602.2.1

SUBJECT: Product Approval

February 21, 2008

Doug Winkler,
Spears Manufacturing Company
4250 Patriot Drive Suite 300
Grapevine, Texas 76051



City of Dallas

RE: Approval for Spears CPVC Acid Waste Piping

Mr. Winkler,

Section 602.2.1 of the 2003-06 International Mechanical Code states that materials exposed within return air plenums shall have a 25/50 fire spread index and developed smoke index when tested in accordance with ASTM E 84.

I have reviewed your request for approval of the Spears CPVC Acid Waste Piping System. I have concluded from the information submitted that this product is approved for use within the City of Dallas for acid waste systems.

This product must be installed according to applicable codes and manufacturer's installation instructions and product listings.

Therefore, use of this product may begin immediately in the City of Dallas.

SIGNATURE: *Lonnie Erwin,*

Chief Plumbing and Mechanical Inspector
City of Dallas