


10/27/2005

Thomas Johnson
1408 Northland Dr. #407
Mendota Heights, MN 55120



CITY OF DALLAS

Subject: TurboChef Technologies - Dallas Texas

Mr. Johnson,

I have reviewed your request for approval of the TurboChef Model NGC Rapid Cook Oven, models identified as C3, Tornado, and High h Batch Speed Cook Ovens and is granted LIMITED exemption from Type I or Type II vent-a-hood requirements of International Mechanical Code under the following conditions.

1. There shall be no more than one unventilated oven at each location.
2. The ovens shall not be used for cooking meats, poultry, fish, or other foods that may produce grease laden vapors. Such use will require a Type I vent-a-hood ventilation system to be installed over the unit.
3. The oven must be installed in a well ventilated area approved for food preparation.
4. Operation of the oven does not impact the environmental air system as outlined by the 2000 International Energy Code.
5. This product must be installed operated, serviced and maintained, according to manufacturer's installation instructions, product listings and all applicable mechanical codes.

This exemption shall remain in effect until revoked. However, should problems arise from the use of the TurboChef Rapid Cook Oven's without a Type I or Type II vent-a-hood ventilation system this exemption may be with drawn.

This letter is not to be used for advertising, promotion or approval of this product.

Therefore, use of this product may begin immediately in the City of Dallas.

Best Regards,

Lonnie Erwin

Lonnie Erwin
Chief Plumbing and Mechanical Inspector
Development Services
Building Inspection
City of Dallas