



CITY OF DALLAS

**CRITERIA FOR REQUIREMENT (NON-RESIDENTIAL SERVICES)
OF A PRIVATE DEVELOPMENT CONTRACT (P-CONTRACT)
WASTEWATER AND LARGE WATER SERVICES**

If the service installation meets **any** of the following criteria, a Private Development Contract will be required:

- Service length is greater than 60 feet as measured from the connection at the existing water main to the centerline of the meter vault
- Service length is greater than 25 feet in a Principal Arterial/Minor Arterial or State Highway
- Water main is reinforced concrete cylinder pipe
- Water main is larger than 16 inches in diameter
- Water and/or Wastewater main extension is required-
 - Unless individual owner with 100 feet or less, as approved by DWU Main Street
- Water and /or wastewater main is more than 20 feet deep
- Located in the Central Business District (area bound by I-45, Woodall Rogers, Stemmons and R. L. Thornton)
- Railroad easement is required
- Suspended water vault required
- Wastewater Manhole is required
 - WW connection to trunk main (over 21") will require WWMH
 - 10" WW Lateral or larger will require WWMH
- Water and/or Wastewater main >20' deep
- Fire Hydrant is required

❖ **Before tapping 12" A.C., Bonded Contractor to call:
Johnny Partain (214) 670-8796**