

SECURITY SYSTEM COMMERCIAL APPLICATION CHECKLIST AND REQUIRED DOCUMENTS

- ☐ 1. Floor plan(s) showing proposed location of electric/electronic locking device(s) drawn to a standard scale and dimensioned.
- ☐ 2. Specifications of device(s) that will be installed including:
 - a. Verification that the device(s) will automatically unlock upon:
 - 1. Activation of the sprinkler system, smoke detection system or building fire alarm system.
 - 2. Loss of electrical power to any of the following:
 - The locking device
 - The smoke detection system
 - The building fire alarm or voice communication system
 - Required exit illumination
 - b. Verification that the device(s) can be unlocked by a signal from a location approved by the Fire Marshal.
 - c. Verification that upon deactivation from any source, the device(s) can only be reset manually at the device(s).
 - d. Verification that devices installed on doors into exit enclosures will maintain the doors in a positively latched position upon automatic release of the device.
- ☐ 3. Statement that signage will be placed at all locations where the device(s) is/are installed in accordance with established guidelines.

OTHER REQUIREMENTS OR SPECIAL PROVISIONS

Security systems operating under 30 volts do not require an electrical permit.

Please note that staff cannot accept incomplete applications or illegible plan review documents.