



**City of Dallas Prescriptive Path  
Project Summary and Checklist - One or Two Family Dwelling Unit  
Addition**

| Summary   |               |                           |                        |   |                      |                  |
|---|---------------|---------------------------|------------------------|---|----------------------|------------------|
| Date of Application   |               |                           |                        |   |                      |                  |
| Compliance Path   |               |                           |                        |   |                      |                  |
| Project Identification  |               |                           |                        |   |                      |                  |
| Project Address   |               |                           |                        |   |                      |                  |
| Owner Identification  |               |                           |                        |   |                      |                  |
| Architect Identification  |               |                           |                        |   |                      |                  |
| Contractor Identification   |               |                           |                        |   |                      | Registration No. |
| Third Party Provider  |               |                           |                        |   |                      |                  |
| Building Code   | IRC           | IBC Residential Occupancy |                        |   |                      |                  |
| Type of Building  | Single Family | Duplex                    | Townhouse*             | IBC Group R Occupancy: R-1 R-2 R-3 R-4 (circle one) |                      |                  |
| Number of:  | Stories:      | Bedrooms:                 | Baths:                 |   |                      |                  |
| Garage  | Attached      |                           | Detached               | Carpport  | None                 |                  |
| Building Sq. Footage  | Lot Size:     |                           | Building Total Sq. Ft: | Area Under Roof:                                    | Total Non roof Area: |                  |
| IECC Climate Zone   | 3A            |                           |                        |   |                      |                  |
| <b>Note:</b>  |               |                           |                        |   |                      |                  |
| <ul style="list-style-type: none"> <li>Buildings shall be designed and constructed in accordance with the Energy provisions of Dallas Energy code. Compliance with IECC must be demonstrated separately by City of Dallas registered Third Party Energy Inspector</li> <li>All requirements mandatory</li> <li>Townhouse: As defined by the Dallas Residential Code; may not be multifamily building</li> </ul> |               |                           |                        |   |                      |                  |



| Prescriptive Provisions |  |   |     |            |    |     |             |   |
|-------------------------|--|---|-----|------------|----|-----|-------------|---|
| Item                    | Green Building Practice  | Plan Review   |     | Inspection |    |     | Field Notes | Comments  |
|                         |  | Yes   | N/A | Yes        | No | N/A |             |   |
| 326.2.2.1.3.2.2         | <b>Water Efficiency</b>  |   |     |            |    |     |             | Submitted at plan review; verify at final inspection  |
|                         | <b>Must meet at least 2 of the following water reduction strategies:</b>                               |   |     |            |    |     |             | Performance properties noted on drawings or specified; review submittal cut sheets; verify at final inspection            |
|                         | 1. The average flow rate for all lavatory faucets must be less than or equal to 2.0 gallons per minute |   |     |            |    |     |             | Average flow rate is per fixture; refer to manufacturer's product literature.   |
|                         | 2. The average flow rate for all shower head must be less than or equal to 2.0 gallons per minute      |   |     |            |    |     |             |   |
|                         | 3. The average flow rate for all toilets must be:  |   |     |            |    |     |             |   |
|                         | 3.1 Less than or equal to 1.3 gallons per flush, or  |   |     |            |    |     |             |   |
|                         | 3.2 Dual flush complying with ASME A 112.19.14, or   |   |     |            |    |     |             |   |
|                         | 3.3 Comply with US EPA Water Sense; certified and labeled  |   |     |            |    |     |             |   |
| 326.2.2.1.3.3           | <b>Energy Efficiency</b>   | <b>All projects must meet with the minimum requirements of the energy provisions of the 2015 IRC.</b> |     |            |    |     |             |   |
| 326.2.2.1.3.4           | <b>Heat Island Mitigation</b>  |   |     |            |    |     |             | Specified on drawings or specifications at Plan Review; documented by construction submittals; verify at Final Inspection |
|                         | Proposed projects shall install any one of the following options:                                      |   |     |            |    |     |             |   |
|                         | <b>Option 1:</b> An ENERGY STAR qualified roof on all roofs with a slope of 2:12 or greater.           |   |     |            |    |     |             |   |
|                         | <b>Option 2:</b> A vegetated roof may be installed subject to approval by the Building Official.       |   |     |            |    |     |             | Must be approved by BI at Plan Review   |





| Prescriptive Provisions  |   |             |     |            |    |     |             |  |
|--------------------------|---|-------------|-----|------------|----|-----|-------------|--|
| Item                     | Green Building Practice   | Plan Review |     | Inspection |    |     | Field Notes | Comments   |
|                          |   | Yes         | N/A | Yes        | No | N/A |             |  |
|                          | <b>Option 3:</b> Radiant barrier with conventional shingles.  |             |     |            |    |     |             | Installation in accordance with manufacturer installation instructions required. Radiant barriers will be considered an alternative path to Energy Star and cool roofs, under the condition that the radiant barrier installation complies with the manufacturer's recommendations which include, but are not limited to: the shiny side of the sheet faces out; the sheet is factory perforated; it is not installed on the attic floor or where the shiny side may become covered with dust; and it is not sandwiched between materials such as insulation and roof shingles. if the radiant barrier is applied to roof sheathing, the radiant barrier must face down into the attic and may not be covered. Radiant barriers have no insulative or R value and are not used in place of insulation. Reflective paint is not considered a radiant barrier. |
|                          | <b>Option 4:</b> Encapsulated foam insulation between the roof rafters (R-22 or greater)  |             |     |            |    |     |             | Installation in accordance with manufacturer installation instructions required  |
| <b>326.2.2.1.3.5</b>     | <b>Indoor Air Quality</b>   |             |     |            |    |     |             | Show on drawings at Plan Review; verify at Final Inspection  |
| <b>326.2.2.1.3.5.1</b>   | <b>HVAC:</b> All air-handling equipment and ductwork must be outside the fire-rated envelope of the garage.   |             |     |            |    |     |             |  |
| <b>326.2.2.1.3.5.2</b>   | <b>Minimize Pollutants from the garage:</b>   |             |     |            |    |     |             |  |
| <b>326.2.2.1.3.5.2.1</b> | <b>Conditioned Spaces above a garage:</b><br>1. Penetrations sealed<br>2. Floor and ceiling joist bays sealed<br>3. Painted walls and ceilings of conditioned spaces. |             |     |            |    |     |             |  |





City of Dallas

| Prescriptive Provisions |   |             |     |            |    |     |             |          |
|-------------------------|---|-------------|-----|------------|----|-----|-------------|----------|
| Item                    | Green Building Practice   | Plan Review |     | Inspection |    |     | Field Notes | Comments |
|                         |   | Yes         | N/A | Yes        | No | N/A |             |          |
| 326.2.2.1.3.5.2.2       | <b>Conditioned Spaces next to a garage:</b><br>1. Penetration sealed<br>2. Doors weather stripped<br>3. Cracks at wall base sealed          |             |     |            |    |     |             |          |
| 326.2.2.1.3.5.3         | <b>Air Filters</b><br>a. MERV 8 of greater<br>b. Air handlers sized to maintain air pressure and air flow<br>c. Airtight air filter housing |             |     |            |    |     |             |          |
|                         |   |             |     |            |    |     |             |          |
|                         | End of Prescriptive   |             |     |            |    |     |             |          |

