

# FIRE ALARM SYSTEM INFORMATION CHECKLIST



CITY OF DALLAS

## REQUIRED DOCUMENTS FOR FIRE ALARM SYSTEMS

### OTHER REQUIREMENTS OR SPECIAL PROVISIONS

FIRE ALARM PERMITS ARE ISSUED AS A SERVICE FOR THE FIRE PREVENTION, EDUCATION AND INSPECTION (F.P.E. & I.) SECTION OF THE DALLAS FIRE DEPARTMENT. ALL PLANS AND SPECIFICATIONS SHOULD BE SUBMITTED TO F.P.E. & I. AT 2014 MAIN STREET, ROOM 406, FOR PLAN REVIEW AND APPROVAL. SEE ATTACHED FORM FROM FIRE DEPARTMENT.

An approved fire alarm system must be installed in accordance with the Fire Code in all of the following occupancies:

- Assembly - Group A-1, A-2 and A-2.1
- Education - Group E with an occupant load of 50 or more persons
- Hazardous - Group H used for the manufacture of organic coatings; approved automatic smoke detection shall be provided for rooms used for storage, dispensing, use and handling of hazardous materials when required by the Fire Code; Group H, Division 6 Occupancies
- Institutional - Group I Occupancies (all)
- Residential - Group R, Division 1 apartments 3 or more stories in height or having 16 or more dwelling units, in hotels 3 or more stories in height or having 20 or more guest rooms, and in congregate residences 3 or more stories in height or having an occupant load of 20 or more
- High-rise buildings
- Amusement buildings
- Whenever required by the Fire Code

I, \_\_\_\_\_ have read the above information and acknowledge that all required documents have been provided.

Please Print

Signature \_\_\_\_\_

Date \_\_\_\_\_

Building Inspection Division

320 E. Jefferson Blvd.

Dallas, TX 75203

Telephone 214-948-4480

Staff cannot accept incomplete or illegible documents

Revised 7/2000