



CITY OF DALLAS

Flammable Liquid Additional Requirements

If underground storage tank or piping (UST) installation, TCEQ certification notice must be provided.

If UST piping, a copy of UST installer license must be provided.

If UST or piping, a copy of Texas Liability insurance must be provided.